Section 55 Protection of the Environment Operations Act 1997

Environment Protection Licence

Licence - 12633

Department of **Environment & Climate Change** NSW

Licence Details	
Number:	12633
Anniversary Date:	20-March
Review Due Date:	20-Mar-2012

Licensee
GOSFORD CITY COUNCIL
PO BOX 21
GOSFORD NSW 2250

Licence Type
Premises

Premises
MOONEY MOONEY AND CHEERO POINT SEWERAGE SCHEME
-
MOONEY MOONEY NSW 2083

Scheduled Activity
Sewage treatment

Fee Based Activity	**Scale**
Sewage treatment - processing by small plants (< 10000 ML per year)	> 20 - 100 ML discharged

Region
North East - Hunter
Ground Floor, NSW Govt Offices, 117 Bull Street
NEWCASTLE WEST NSW 2302
Phone: 02 49086800
Fax: 02 49086810
PO Box 488G NEWCASTLE
NSW 2300

INFORMATION ABOUT THIS LICENCE **4**
Dictionary 4
Responsibilities of licensee 4
Variation of licence conditions 4
Duration of licence 4
Licence review 4
Fees and annual return to be sent to the EPA 4
Transfer of licence 5
Public register and access to monitoring data 5
1 ADMINISTRATIVE CONDITIONS **5**
A1 What the licence authorises and regulates 5
A2 Premises to which this licence applies 6
A3 Other activities 7
A4 Information supplied to the EPA 7
2 DISCHARGES TO AIR AND WATER AND APPLICATIONS TO LAND **7**
P1 Location of monitoring/discharge points and areas 7
Note: Effluent from the Mooney Mooney and Cheero Point Sewerage System is conveyed to the 7
3 LIMIT CONDITIONS **8**
L1 Pollution of waters 8
L2 Load limits 8
L3 Concentration limits 8
L4 Volume and mass limits 8
L5 Waste 8
L6 Noise Limits 9
L7 Potentially offensive odour 9
4 OPERATING CONDITIONS **9**
O1 Activities must be carried out in a competent manner 9
O2 Maintenance of plant and equipment 9
O3 Dust Control 9
O4 New sewage pumping stations 9
O5 Reticulation system 10
O6 Prohibition on acceptance of pesticides 10
5 MONITORING AND RECORDING CONDITIONS **10**
M1 Monitoring records 10
M2 Requirement to monitor concentration of pollutants discharged 10
M3 Testing methods - concentration limits 10
M4 Recording of pollution complaints 11
M5 Telephone complaints line 11
M6 Requirement to monitor volume or mass 11

M7 Requirement to record overflows 12

6 REPORTING CONDITIONS 12

R1 Annual return documents 12

R2 Notification of environmental harm 13

R3 Written report 13

R4 Notification of overflow incidents 14

R5 Annual System Performance Report 15

GENERAL CONDITIONS 15

G1 Copy of licence kept at the premises 15

G2 Signage 15

G3 Contact number for incidents and responsible employees 15

G4 Incident response 16

POLLUTION STUDIES AND REDUCTION PROGRAMS 16

U1 Not applicable. 16

SPECIAL CONDITIONS 16

DICTIONARY 16

General Dictionary 16

Information about this licence

Dictionary

A definition of terms used in the licence can be found in the dictionary at the end of this licence.

Responsibilities of licensee

Separate to the requirements of this licence, general obligations of licensees are set out in the Protection of the Environment Operations Act 1997 ("the Act") and the Regulations made under the Act. These include obligations to:

- ensure persons associated with you comply with this licence, as set out in section 64 of the Act;
- control the pollution of waters and the pollution of air (see for example sections 120 - 132 of the Act); and
- report incidents causing or threatening material environmental harm to the environment, as set out in Part 5.7 of the Act.

Variation of licence conditions

The licence holder can apply to vary the conditions of this licence. An application form for this purpose is available from the EPA.

The EPA may also vary the conditions of the licence at any time by written notice without an application being made.

Where a licence has been granted in relation to development which was assessed under the Environmental Planning and Assessment Act 1979 in accordance with the procedures applying to integrated development, the EPA may not impose conditions which are inconsistent with the development consent conditions until the licence is first reviewed under Part 3.6 of the Act.

Duration of licence

This licence will remain in force until the licence is surrendered by the licence holder or until it is suspended or revoked by the EPA or the Minister. A licence may only be surrendered with the written approval of the EPA.

Licence review

The Act requires that the EPA review your licence at least every 5 years after the issue of the licence, as set out in Part 3.6 and Schedule 5 of the Act. You will receive advance notice of the licence review.

Fees and annual return to be sent to the EPA

For each licence fee period you must pay:

- an administrative fee; and
- a load-based fee (if applicable).

The EPA publication "A Guide to Licensing" contains information about how to calculate your licence fees.

The licence requires that an Annual Return, comprising a Statement of Compliance and a summary of any monitoring required by the licence (including the recording of complaints), be submitted to the EPA. The Annual Return must be submitted within 60 days after the end of each reporting period. See condition R1 regarding the Annual Return reporting requirements.

Usually the licence fee period is the same as the reporting period.

Transfer of licence

The licence holder can apply to transfer the licence to another person. An application form for this purpose is available from the EPA.

Public register and access to monitoring data

Part 9.5 of the Act requires the EPA to keep a public register of details and decisions of the EPA in relation to, for example:

- licence applications;
- licence conditions and variations;
- statements of compliance;
- load based licensing information; and
- load reduction agreements.

Under s320 of the Act application can be made to the EPA for access to monitoring data which has been submitted to the EPA by licensees.

This licence is issued to:

GOSFORD CITY COUNCIL
PO BOX 21
GOSFORD NSW 2250

subject to the conditions which follow.

1 Administrative conditions

A1 What the licence authorises and regulates

A1.1 This licence authorises the carrying out of the scheduled development work listed below at the premises listed in A2.
Construction of the Mooney Mooney and Cheero Point sewerage reticulation system and transfer pipeline over the Hawkesbury River as part of the Lower Hawkesbury Sewerage System.

A1.2 This licence authorises the carrying out of the scheduled activities listed below at the premises

specified in A2. The activities are listed according to their scheduled activity classification, fee-based activity classification and the scale of the operation.

Unless otherwise further restricted by a condition of this licence, the scale at which the activity is carried out must not exceed the maximum scale specified in this condition.

Scheduled Activity
Sewage treatment

Fee Based Activity	Scale
Sewage treatment - processing by small plants (< 10000 ML per year)	> 20 - 100 ML discharged

A1.3 The licensee must not carry on any scheduled activities until the scheduled development works are completed, except as elsewhere provided in this licence.

A2 Premises to which this licence applies

A2.1 The licence applies to the following premises:

Premises Details
MOONEY MOONEY AND CHEERO POINT SEWERAGE SCHEME
-
MOONEY MOONEY
NSW
2083

Premises Details
The sewerage reticulation system within the Gosford Local Government Area as shown on the figures titled "Mooney Mooney and Cheero Point Sewerage Scheme, Pressure Sewerage Reticulation Main, Sheets 01-06 " presented in the "Concept Design Report" dated November 2006.

A3 Other activities

A3.1 Not applicable.

A4 Information supplied to the EPA

A4.1 Works and activities must be carried out in accordance with the proposal contained in the licence application, except as expressly provided by a condition of this licence.

In this condition the reference to "the licence application" includes a reference to:
(a) the applications for any licences (including former pollution control approvals) which this licence replaces under the Protection of the Environment Operations (Savings and Transitional) Regulation 1998; and
(b) the licence information form provided by the licensee to the EPA to assist the EPA in connection with the issuing of this licence.

2 Discharges to air and water and applications to land

P1 Location of monitoring/discharge points and areas

P1.1 Not applicable.

P1.2 Not applicable.

P1.3 Not applicable.

Note: Effluent from the Mooney Mooney and Cheero Point Sewerage System is conveyed to the Brooklyn Sewage Treatment System (Environment Protection Licence 12438) for treatment and disposal.

3 Limit conditions

L1 Pollution of waters

L1.1 Except as may be expressly provided in any other condition of this licence, the licensee must comply with section 120 of the Protection of the Environment Operations Act 1997.

L1.2 This licence does not permit the pollution of water at any time during dry weather from any pumping station.

L2 Load limits

L2.1 Not applicable.

L2.2 Not applicable.

L3 Concentration limits

L3.1 Not applicable.

L3.2 Not applicable.

L3.3 Not applicable.

L4 Volume and mass limits

L4.1 Not applicable.

L5 Waste

L5.1 The licensee must not cause, permit or allow any waste generated outside the premises to be received at the premises for storage, treatment, processing, reprocessing or disposal or any waste generated at the premises to be disposed of at the premises, except as expressly permitted by the licence.

L5.2 This condition only applies to the storage, treatment, processing, reprocessing or disposal of waste at the premises if those activities require an environment protection licence.

L6 Noise Limits

L6.1 Not applicable.

L7 Potentially offensive odour

L7.1 No condition of this licence identifies a potentially offensive odour for the purposes of section 129 of the Protection of the Environment Operations Act 1997.

Note: Section 129 of the Protection of the Environment Operations Act 1997, provides that the licensee must not cause or permit the emission of any offensive odour from the premises but provides a defence if the emission is identified in the relevant environment protection licence as a potentially offensive odour and the odour was emitted in accordance with the conditions of a licence directed at minimising odour.

4 Operating conditions

O1 Activities must be carried out in a competent manner

O1.1 Licensed activities must be carried out in a competent manner.

This includes:
(a) the processing, handling, movement and storage of materials and substances used to carry out the activity; and
(b) the treatment, storage, processing, reprocessing, transport and disposal of waste generated by the activity.

O2 Maintenance of plant and equipment

O2.1 All plant and equipment installed at the premises or used in connection with the licensed activity:
(a) must be maintained in a proper and efficient condition; and
(b) must be operated in a proper and efficient manner.

O3 Dust Control

O3.1 All operations and activities occurring at the premises must be carried out in a manner that will minimise the emission of dust from the premises.

O4 New sewage pumping stations

O4.1 All sewage pumping stations which are installed within the sewage treatment system after the date of issue of this licence must be designed and constructed in such a way that there will be no discharge from the sewage pumping station in dry weather.

O5 Reticulation system

O5.1 The licensee must ensure that the reticulation system is planned, designed, constructed and installed to prevent discharges of sewage or partially treated sewage from the premises.

O6 Prohibition on acceptance of pesticides

O6.1 The licensee must not consent to any discharge of organophosphate pesticides (including chlorpyrifos, diazinon, malathion) or organochlorine pesticides (including dieldrin, heptachlor and chlordane) into the sewage treatment system.

5 Monitoring and recording conditions

M1 Monitoring records

M1.1 The results of any monitoring required to be conducted by this licence or a load calculation protocol must be recorded and retained as set out in this condition.

M1.2 All records required to be kept by this licence must be:
(a) in a legible form, or in a form that can readily be reduced to a legible form;
(b) kept for at least 4 years after the monitoring or event to which they relate took place; and
(c) produced in a legible form to any authorised officer of the EPA who asks to see them.

M1.3 The following records must be kept in respect of any samples required to be collected for the purposes of this licence:
(a) the date(s) on which the sample was taken;
(b) the time(s) at which the sample was collected;
(c) the point at which the sample was taken; and
(d) the name of the person who collected the sample.

M2 Requirement to monitor concentration of pollutants discharged

M2.1 Not applicable.

M3 Testing methods - concentration limits

M3.1 Not applicable.

M3.2 Not applicable.

M4 Recording of pollution complaints

M4.1 The licensee must keep a legible record of all complaints made to the licensee or any employee or agent of the licensee in relation to pollution arising from any activity to which this licence applies.

M4.2 The record must include details of the following:
(a) the date and time of the complaint;
(b) the method by which the complaint was made;
(c) any personal details of the complainant which were provided by the complainant or, if no such details were provided, a note to that effect;
(d) the nature of the complaint;
(e) the action taken by the licensee in relation to the complaint, including any follow-up contact with the complainant; and
(f) if no action was taken by the licensee, the reasons why no action was taken.

M4.3 The record of a complaint must be kept for at least 4 years after the complaint was made.

M4.4 The record must be produced to any authorised officer of the EPA who asks to see them.

M5 Telephone complaints line

M5.1 The licensee must operate during its operating hours a telephone complaints line for the purpose of receiving any complaints from members of the public in relation to activities conducted at the premises or by the vehicle or mobile plant, unless otherwise specified in the licence.

M5.2 The licensee must notify the public of the complaints line telephone number and the fact that it is a complaints line so that the impacted community knows how to make a complaint.

M5.3 Conditions M5.1 and M5.2 do not apply until 3 months after:
(a) the date of the issue of this licence or
(b) if this licence is a replacement licence within the meaning of the Protection of the Environment Operations (Savings and Transitional) Regulation 1998, the date on which a copy of the licence was served on the licensee under clause 10 of that regulation.

M6 Requirement to monitor volume or mass

M6.1 Not applicable.

M7 Requirement to record overflows

M7.1 From 1 June 2009 the licensee must record the following details in relation to each observed or reported overflow from the reticulation system:

(a) the location of the overflow;
(b) the date, estimated start time and estimated duration of the overflow;
(c) the estimated volume of the overflow;
(d) a description of the receiving environment of the overflow;
(e) classification as a dry or wet weather overflow;
(f) the probable cause of the overflow;
(g) any actions taken to stop the overflow happening;
(h) any actions taken to clean up the overflow; and
(i) any actions taken to prevent the overflow happening again.

6 Reporting conditions

R1 Annual return documents

What documents must an Annual Return contain?

R1.1 The licensee must complete and supply to the EPA an Annual Return in the approved form comprising:
(a) a Statement of Compliance; and
(b) a Monitoring and Complaints Summary.
A copy of the form in which the Annual Return must be supplied to the EPA accompanies this licence. Before the end of each reporting period, the EPA will provide to the licensee a copy of the form that must be completed and returned to the EPA.

Period covered by Annual Return

R1.2 An Annual Return must be prepared in respect of each reporting period, except as provided below.

Note: The term "reporting period" is defined in the dictionary at the end of this licence. Do not complete the Annual Return until after the end of the reporting period.

R1.3 Where this licence is transferred from the licensee to a new licensee:
(a) the transferring licensee must prepare an Annual Return for the period commencing on the first day of the reporting period and ending on the date the application for the transfer of the licence to the new licensee is granted; and
(b) the new licensee must prepare an Annual Return for the period commencing on the date the application for the transfer of the licence is granted and ending on the last day of the reporting period.

Note: An application to transfer a licence must be made in the approved form for this purpose.

R1.4 Where this licence is surrendered by the licensee or revoked by the EPA or Minister, the licensee must prepare an Annual Return in respect of the period commencing on the first day of the reporting period and ending on:
(a) in relation to the surrender of a licence - the date when notice in writing of approval of the surrender is given; or
(b) in relation to the revocation of the licence - the date from which notice revoking the licence operates.

Deadline for Annual Return

R1.5 The Annual Return for the reporting period must be supplied to the EPA by registered post not later than 60 days after the end of each reporting period or in the case of a transferring licence not later than 60 days after the date the transfer was granted (the 'due date').

Notification where actual load can not be calculated

R1.6 Not applicable.

Licensee must retain copy of Annual Return

R1.7 The licensee must retain a copy of the Annual Return supplied to the EPA for a period of at least 4 years after the Annual Return was due to be supplied to the EPA.

Certifying of Statement of Compliance and signing of Monitoring and Complaints Summary

R1.8 Within the Annual Return, the Statement of Compliance must be certified and the Monitoring and Complaints Summary must be signed by:
(a) the licence holder; or
(b) by a person approved in writing by the EPA to sign on behalf of the licence holder.

R1.9 A person who has been given written approval to certify a certificate of compliance under a licence issued under the Pollution Control Act 1970 is taken to be approved for the purpose of this condition until the date of first review of this licence.

R2 Notification of environmental harm

Note: The licensee or its employees must notify the EPA of incidents causing or threatening material harm to the environment as soon as practicable after the person becomes aware of the incident in accordance with the requirements of Part 5.7 of the Act.

R2.1 Notifications must be made by telephoning the EPA's Pollution Line service on 131 555.

R2.2 The licensee must provide written details of the notification to the EPA within 7 days of the date on which the incident occurred.

R3 Written report

R3.1 Where an authorised officer of the EPA suspects on reasonable grounds that:
(a) where this licence applies to premises, an event has occurred at the premises; or
(b) where this licence applies to vehicles or mobile plant, an event has occurred in connection with the carrying out of the activities authorised by this licence,

and the event has caused, is causing or is likely to cause material harm to the environment (whether the harm occurs on or off premises to which the licence applies), the authorised officer may request a written report of the event.

R3.2 The licensee must make all reasonable inquiries in relation to the event and supply the report to the EPA within such time as may be specified in the request.

R3.3 The request may require a report which includes any or all of the following information:
(a) the cause, time and duration of the event;
(b) the type, volume and concentration of every pollutant discharged as a result of the event;
(c) the name, address and business hours telephone number of employees or agents of the licensee, or a specified class of them, who witnessed the event;
(d) the name, address and business hours telephone number of every other person (of whom the licensee is aware) who witnessed the event, unless the licensee has been unable to obtain that information after making reasonable effort;
(e) action taken by the licensee in relation to the event, including any follow-up contact with any complainants;
(f) details of any measure taken or proposed to be taken to prevent or mitigate against a recurrence of such an event; and
(g) any other relevant matters.

R3.4 The EPA may make a written request for further details in relation to any of the above matters if it is not satisfied with the report provided by the licensee. The licensee must provide such further details to the EPA within the time specified in the request.

R4 Notification of overflow incidents

R4.1 Where either:
(a) sewage or partially treated sewage is discharged from the premises as a result of a bypass of the sewage treatment plant, or
(b) an observed or reported overflow has occurred from the reticulation system,

and the overflow or bypass may result in a significant risk to public health, the licensee is to promptly give appropriate notification to any parties that are likely to be affected, such as:
(i) the EPA's Pollution Line service on 131 555,
(ii) the NSW Department of Public Health; and
(iii) local council(s) where relevant.

R4.2 The Licensee must notify the SafeFood NSW of incidents of significance to shellfish production. This notification is to be given as soon as practicable after the licensee or one of the licensee's employees or agents becomes aware that the incident may be of significance to shellfish production.

R4.3 When the licensee notifies the Department of Health or Safe Food NSW Shellfish Quality Assurance Program of a bypass or overflow incident, the licensee must also notify the EPA by

telephoning its Pollution Line service on 131 555. Notifications are to be given as soon as practicable after the licensee or one of the licensee's employees or agents becomes aware of the incident, and must include all relevant information including the information required under this licence.

R5 Annual System Performance Report

R5.1 The licensee must supply to the EPA an Annual System Performance Report not later than 60 days after the end of each reporting period.

R5.2 The Report is to supplement the Annual Return and must include but need not be limited to:

(a) a summary of observed, reported or recorded wet weather and dry weather overflows. These data are to be for the current reporting period and for the previous twelve-month periods, up to a maximum of four, for which data has been required to be collected. Any significant actions taken to address overflows are to be noted.

General conditions

G1 Copy of licence kept at the premises

G1.1 A copy of this licence must be kept at the premises to which the licence applies.

G1.2 The licence must be produced to any authorised officer of the EPA who asks to see it.

G1.3 The licence must be available for inspection by any employee or agent of the licensee working at the premises.

G2 Signage

G2.1 Not applicable.

G3 Contact number for incidents and responsible employees

G3.1 The licensee must operate 24-hour telephone contact lines for the purpose of enabling the EPA to directly contact one or more representatives of the licensee who can:
(a) respond at all times to incidents relating to the premises, and
(b) contact the licensee's senior employees or agents authorised at all times to:
(i) speak on behalf of the licensee

(ii) provide any information or document required under this licence.

G3.2 The licensee is to inform the EPA of the representative or representatives and their telephone number within 3 months of the date of the issue of this licence. The EPA must be notified of the telephone number on commencement of its operation.

G3.3 The licensee is to inform the EPA in writing of the appointment of any subsequent contact persons, or changes to the person's contact details as soon as practicable and in any event within fourteen days of the appointment or change.

G4 Incident response

G4.1 In the event of an incident that harms or is likely to harm the environment, the licensee must use all practicable measures to minimise the impact of the incident on the environment and public health.

Pollution studies and reduction programs

U1 Not applicable.

Special conditions

Dictionary

General Dictionary

In this licence, unless the contrary is indicated, the terms below have the following meanings:

3DGM [in relation to a concentration limit]	Means the three day geometric mean, which is calculated by multiplying the results of the analysis of three samples collected on consecutive days and then taking the cubed root of that amount. Where one or more of the samples is zero or below the detection limit for the analysis, then 1 or the detection limit respectively should be used in place of those samples
Act	Means the Protection of the Environment Operations Act 1997
activity	Means a scheduled or non-scheduled activity within the meaning of the Protection of the Environment Operations Act 1997
actual load	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
AM	Together with a number, means an ambient air monitoring method of that number prescribed by the *Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales*.
AMG	Australian Map Grid
anniversary date	The anniversary date is the anniversary each year of the date of issue of the licence. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.

annual return	Is defined in R1.1
Approved Methods Publication	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
assessable pollutants	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
BOD	Means biochemical oxygen demand
CEM	Together with a number, means a continuous emission monitoring method of that number prescribed by the *Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales*.
COD	Means chemical oxygen demand
composite sample	Unless otherwise specifically approved in writing by the EPA, a sample consisting of 24 individual samples collected at hourly intervals and each having an equivalent volume.
cond.	Means conductivity
environment	Has the same meaning as in the Protection of the Environment Operations Act 1997
environment protection legislation	Has the same meaning as in the Protection of the Environment Administration Act 1991
EPA	Means Environment Protection Authority of New South Wales.
fee-based activity classification	Means the numbered short descriptions in Schedule 1 of the Protection of the Environment Operations (General) Regulation 1998.
flow weighted composite sample	Means a sample whose composites are sized in proportion to the flow at each composites time of collection.
general solid waste (non-putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
general solid waste (putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
grab sample	Means a single sample taken at a point at a single time
hazardous waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
licensee	Means the licence holder described at the front of this licence
load calculation protocol	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
local authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
material harm	Has the same meaning as in section 147 Protection of the Environment Operations Act 1997
MBAS	Means methylene blue active substances
Minister	Means the Minister administering the Protection of the Environment Operations Act 1997
mobile plant	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
motor vehicle	Has the same meaning as in the Protection of the Environment Operations Act 1997
O&G	Means oil and grease

percentile [in relation to a concentration limit of a sample]	Means that percentage [eg.50%] of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time. In this licence, the specified period of time is the Reporting Period unless otherwise stated in this licence.
plant	Includes all plant within the meaning of the Protection of the Environment Operations Act 1997 as well as motor vehicles.
pollution of waters [or water pollution]	Has the same meaning as in the Protection of the Environment Operations Act 1997
premises	Means the premises described in condition A2.1
public authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
regional office	Means the relevant EPA office referred to in the Contacting the EPA document accompanying this licence
reporting period	For the purposes of this licence, the reporting period means the period of 12 months after the issue of the licence, and each subsequent period of 12 months. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
restricted solid waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
scheduled activity	Means an activity listed in Schedule 1 of the Protection of the Environment Operations Act 1997
special waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
TM	Together with a number, means a test method of that number prescribed by the *Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales*.
TSP	Means total suspended particles
TSS	Means total suspended solids
Type 1 substance	Means the elements antimony, arsenic, cadmium, lead or mercury or any compound containing one or more of those elements
Type 2 substance	Means the elements beryllium, chromium, cobalt, manganese, nickel, selenium, tin or vanadium or any compound containing one or more of those elements
utilisation area	Means any area shown as a utilisation area on a map submitted with the application for this licence
waste	Has the same meaning as in the Protection of the Environment Operations Act 1997
waste type	Means liquid, restricted solid waste, general solid waste (putrescible), general solid waste (non-putrescible), special waste or hazardous waste

approved	Means approved in writing by the EPA. The EPA's approval may be given unconditionally, or subject to conditions.
average concentration limit	Means the average of twelve monitoring test results undertaken during the reporting period.
average dry weather flow (ADWF)	Means the average flow at a point calculated or measured over a 24 hour period in dry weather
Biosolids	Has the same meaning as in Schedule 1, Part 3 of the *Protection of the Environment Operations Act 1997*.
Biosolids	Means the "Environmental Guidelines: Use and disposal of biosolids products" published by the EPA

Guidelines	November 1997, or any subsequently updated guidelines which replace this publication.
bypass	Means circumstances where sewage has been received at the sewage treatment plant but is discharged from the plant without it being treated, processed or reprocessed by means of any or all of the designed treatment processes of the plant. A new bypass event is defined as a bypass that commences at least 24 hours after the end of the previous bypass.
catchment	Catchment boundaries are marked on the system map
cfu	Means colony forming units.
choke	Means a full or partial blockage in a sewer pipe that results in sewage being discharged to the environment. A choke may be caused by structural collapse of the sewer pipes, tree roots, debris or siltation.
condition	Means a condition of this licence.
directed overflow	Means an overflow from a directed overflow structure.
directed overflow structure	Means a designed structure (excluding access chambers) in the reticulation system which operates as a relief to allow sewage to discharge at a planned location or a sewage pumping station, but does not include a bypass from a sewage treatment plant.
discharge	Has the same meaning as in Schedule 1, classification [71] of the *Protection of the Environment Operations (General) Regulation 1998*.
dry weather	Dry weather occurs when less than 10 millimitres of rainfall has been measured at a rain gauge in the catchment of the sewage treatment system during a 24 hour period (where there is no rain gauge in the catchment, at the rain gauge closest to the centre of the catchment). Dry weather SPS discharge occurs when less than 10mm rainfall has been measured at a rain gauge in the catchment of the SPS during a 24 hour period (where there is no rain gauge in the catchment at the rain gauge closest to the SPS).
dry weather overflow	Means an overflow in the reticulation system not caused by wet weather, as determined by the hydraulic sewer system model.
effluent	Means sewage that has received all of the designed treatment processes at the sewage treatment plant.
emission factor	In relation to load-based licensing, means the level of emissions expected to be generated relative to another characteristic of the activity.
harm	Has the same meaning as in the *Protection of the Environment Operations Act 1997*.
kL	Means kilolitre.
L/s	Means litres per second.
leakage	Overflows caused by the exfiltration of sewage from faults, such as cracks, in sewer pipes to the surrounding environment.
licence issue date	Means the date of the issue of this licence, or if this licence is a replacement licence within the meaning of the Protection of the Environment Operations (Savings and Transitional) Regulation 1998, the date on which a copy of the licence was served on the licensee under clause 10 of that regulation.
mL	Means millilitres.
ML	Means megalitres.
node	Is a point in the hydraulic sewer system model that represents one or more overflows in the same catchment.
offensive odour	Has the same meaning as in the *Protection of the Environment Operations Act 1997*.
overflow	Is a discharge of untreated or partially treated sewage from the sewage treatment system. Overflows may occur as directed overflows, uncontrolled overflows, sewage treatment plant wet weather overflows or bypasses.

performance acceptance criteria	In relation to hydraulic sewer stem model, means the standard of accuracy (sometimes called the "goodness of fit") to be achieved when observations of a particular performance indicator are compared to the results predicted by the model.
reticulation system	Means that part of the sewage treatment system which collects and transports sewage to the sewage treatment plant and includes all sewer pipes (whether greater or less than 300mm diameter), access chambers, vent shafts, directed overflow structures and sewage pumping stations, but does not include the sewage treatment plant.
SCAMP	Sewer Catchment Asset Management Plan
sewage	Means all material received in the reticulation system.
sewage products	Means any by-product of the treatment processes and includes biosolids, raw sludge, liquid sludge, thickened sludge, digested sludge, screenings and grit.
sewage pumping station (SPS)	Is a structure which controls the transport of sewage through the sewer pipes, where steep hills and other variations in the land topography can prevent or limit the gravity flow of sewage to the sewage treatment plant.
sewage treatment plant (STP)	Is a facility at which sewage is stored and treated following delivery from the reticulation system prior to discharge, and includes discharge structures and STP bypass points.
sewage treatment system	Means the reticulation system and the sewage treatment plant used for the transport, treatment and discharge of effluent and sewage.
sub-catchment	Sub-catchment boundaries are marked on the system map
ten year rainfall time series data	Means the rainfall data for the period 1985 to 1994 as used in the EISs.
Trade waste agreements	Means agreements reached between the licensee and industrial and commercial customers to restrict the amount of toxic and other potentially harmful substances discharged to the sewerage system.
ug/L	Means micrograms per litre.
uncontrolled overflow	Means an overflow from any part of the reticulation system that is not a directed overflow. Leakage or overflows from access chambers are examples or uncontrolled overflows.
waters	Has the same meaning as in the *Protection of the Environment Operations Act 1997*.
wet weather	Wet weather occurs when 10 millimetres or more of rainfall has been measured at a rain gauge in the catchment of the sewage treatment system during a 24 hour period (where there is no rain gauge in the catchment, at the rain gauge closest to the centre of the catchment).
wet weather overflow	A wet weather overflow in the reticulation system is an overflow caused by wet weather, as determined by the hydraulic sewer system model.

Mr David Darvall

Environment Protection Authority

Department of **Environment & Climate Change** NSW

(By Delegation)

Date of this edition - 14-May-2009

End Notes

1	Condition A1.3 Not applicable varied by notice issued on <issue date> which came into effect on <effective date>
2	Licence varied by notice 1100218, issued on 14-May-2009, which came into effect on 14-May-2009.